

Associated Weavers Europe Industriezone 1 9600 RONSE

Your message - reference	our reference	Gent
<u>-</u>	PW/3599	2023-10-13

Certification report 23/3599

1. Description of the flooring:

Product family	Tufted broadloom carpet
	100% polyester
	Fusion Backing / Action Backing
Total mass	1620 g/m² - 3500 g/m²
Effective pile thickness	4.8 mm – 17.0 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
C _{fl}	Efi	heat flux ≥ 4.5 kW/m²

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



addressee	our reference	Gent	page
Associated Weavers Europe	PW/3599	2023-10-13	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate¹

Cfl - s1

Related commercial names to this product group	Yukon Orinoco Mekong Candide Bizancio Dorado Belcanto Sarno Softissimo Tigris Rio Grande Symphonie Savitri Equator
	Tactille Siripo Ganges
	Nile
	Parana Daydream
The obtained classification is	Centexbel: 23.01547.01 dd 2023-04-13
based on the next test reports	Centexbel: 23.01645.01 dd. 2023-04-21
Validity of the certificate	2028-04-13

Petra Wittevrongel Product Certifier

¹ End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)